

California Department of Public Health Product WorkSheet

Manufacturing Company Information  
 Pentair Residential Filtration, LLC  
 5730 N. Glen Park Road  
 Milwaukee, Wisconsin 53209  
 Phone: (262)-238-4400  
 Website: www.pentairaqua.com

Product Brand: Pentek  
 Product Model: FPS-20BB System  
 CDPH registration # 13-2209  
 Replacement Cartridge FloPlus-20BB

Operating Parameters	SI Units	Metric Units
Service Flow Rate	25.0 gpm	94.6 lpm
System Capacity	X	X
Pressure	30-90 psi	2.1 - 6.1 Kg/cm <sup>2</sup>
Temperature	40-100°F	4.4-37.8°C
Inlet Water Quality Limits		
Turbidity	5 NTU Max.	

Pentek FPS-20BB System Performance Data Sheet				
Contaminant Reduction Claims	Challenge Concentration	Maximum Permissible Product Water Concentration	Reduction Requirements	Reduction Average
Cyst	Minimum 50,000/mL		≥ 99.95%	99.99%

Note: The manufacturer is required to re-test the product every 5 years for material safety, structural integrity and all performance claims made. Any change to the product must be submitted to the certification agency for a technical review. Testing may be required sooner based on the technical review.

**WARNING:** Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Note: The system must be installed and maintained according to manufacturer's recommendations, including replacement of filter cartridges. The contaminants or other substances removed or reduced by this system are not necessarily in your water. Please see Product Installation manual for details.